

## WATKINS Alice

---

**From:** WATKINS Alice  
**Sent:** 14 May 2013 09:02  
**To:** WATKINS Alice  
**Subject:** FW: Weekly List No 16

**Posted At:** 09 May 2013 17:32  
**Posted To:** [planning@oxford.gov.uk](mailto:planning@oxford.gov.uk)  
**Conversation:** Weekly List No 16  
**Subject:** Weekly List No 16

Hi

My comments on Weekly list No 16 are as follows:-

- 13/00653/FUL – 7 Cranston Court – no comment
- 13/00781/FUL – 111 Morrell Ave – drain extension using SUDs methods
- 13/00784/FUL – Cherwell School - drain portakabin using SUDs methods
- 13/00790/DEL – 24 Ouseley Close - drain extension using SUDs methods including porous surfaces
- 13/00796/FUL – 25 The Slade - drain extension using SUDs methods
- 13/00801/FUL – 55 Princess St - drain extension using SUDs methods
- 13/00818/ADV – Tesco Stores – no comment
- 13/00821/FUL – 371 Woodstock Rd – no comment
- 13/00823/FUL – 19 The Slade - drain extension using SUDs methods
- 13/00825/VAR – 2 Coolidge Close – no comment
- 13/00828/FUL – 10 Salegate Lane - drain extension using SUDs methods
- 13/00836/FUL – 35 Sunderland Ave - drain extensions using SUDs methods
- 13/00838/FUL – 35 Downside Rd - drain extension using SUDs methods
- 13/00839/VAR – 56 Oliver Rd – no comment
- 13/00849/ADV – 106 London Rd – no comment
- 13/00860/FUL – Bon Accord Kiln Lane - drain development using SUDs methods including porous surfaces
- 13/00877/FUL – 26 BulaN Rd - drain extension using SUDs methods
- 13/00890/FUL – 37 Crescent Rd – no comment
- 13/00375/FUL – 32 Morrell Ave – no comment
- 13/00768/FUL – 17,19 & 21 Dynham Place - drain parking areas using SUDs methods including porous surfaces
- 13/00791/FUL – 10 Meadow Prospect - drain extension using SUDs methods
- 13/00811/FUL – 30 Cowley Rd – no comment
- 13/00891/FUL – Tesco Stores – no comment
- 13/00820/FUL – 82,84 &86 Windmill Rd - drain development using SUDs methods including porous paving
- 13/00824/FUL – 50 Elmthorpe Rd - drain extension using SUDs methods
- 13/00826/FUL – 38 Cherwell Drive – no comment
- 13/00841/FUL – 56 Victoria Rd – drain extension using SUDs methods
- 13/00859/ADV – 53 Collinwood Rd – no comment
- 13/00891/EXT – 70 London Rd – no comment
- 13/00639/FUL – 6 Nelson St - drain extension using SUDs methods
- 13/00745/FUL – 30 Nelson St - drain extension using SUDs methods

- 13/00747/FUL – 109 Jack Straws Lane - drain extension using SUDs methods including porous surfaces
- 13/00868/FUL – 20 Norham Gardens – no comment
- 13/00880/FUL – 29 Old High St - drain extension using SUDs methods including porous surfaces
- 13/00882/CAC – 29 Old High St – no comment
- 13/00844/CAC – Ox Registry Office - development using SUDs methods including porous surfaces
- 13/00069/LBD – 7 Barton Village Rd – no comment
- 13/00097/FUL – 7 Barton Village Rd - drain development using SUDs methods including porous surfaces
- 13/00303/FUL – Ox Stadium - drain development using SUDs methods including porous surfaces
- 13/00553/ADV – 125 High St – no comment
- 13/00562/LBC – 3-4 Covered Market – no comment
- 13/00776/FUL – Somerville College - drain extension using SUDs methods
- 13/00832/FUL – Ruskin College Site – no comment
- 13/00837/CAC – Ruskin College Site - drain development using SUDs methods including porous surfaces
- 13/00837/CEU – 78 Southmoor Rd – no comment

Regards

Gordon Hunt

County Drainage Engineer

This email, including attachments, may contain confidential information. If you have received it in error, please notify the sender by reply and delete it immediately. Views expressed by the sender may not be those of Oxfordshire County Council. Council emails are subject to the Freedom of Information Act 2000.

<http://www.oxfordshire.gov.uk/emaildisclaimer>